



0013

# PHYSICAL TESTING REPORT

# CERAM

Queens Road, Penkhull, Stoke-on-Trent,  
Staffordshire ST4 7LQ, United Kingdom

tel: +44 (0)845 026 0902

fax: +44 (0)1782 412331

email: enquiries@ceram.com

web: www.ceram.com

**Far Eastern European Trading Company Ltd**  
Unit 17  
Rotherhithe Business Estate  
214 Rotherhithe New Road  
London  
SE16 3EH

FAO: Mr Mike Hayward

**REPORT OF TESTS ON:** Porcela Bobo Porcel-Thin

**Your Reference:** C1

**CERAM Reference:** (12831)-3504

**Date Reported** 02-Mar-2012

**Order Number:** N/A

**Date Logged** 14-Feb-2012

**Date(s) of Test(s):** 21-Feb-2012 to 21-Feb-2012

**Determination of Thermal Shock**

**BSENISO 10545-9: 1996**

**Test Results:**

Description of Test Specimen(s): 5 tiles

Thermal Shock Result: There was **NO EVIDENCE** of damage to the tiles

The test is carried out using a total immersion method.

Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.

**End of Test Report**

S Hall  
Authorised Signatory

